



12/1/2023

Work Order: 23K1987
Project: [none]

Lakeview Water
Attn: Chad Kramer
PO Box 334
Oakley, UT 84055

Client Service Contact: 801.262.7299

The analyses presented on this report were performed in accordance with the National Environmental Laboratory Accreditation Program (NELAP) unless noted in the comments, flags, or case narrative. If the report is to be used for regulatory compliance, it should be presented in its entirety, and not be altered.



Approved By:

Dave Gayer, Project Manager

Certificate of Analysis

Lab Sample No.: 23K1987-01

Name: Lakeview Water

Sample Date: 11/27/2023 1:52 PM

Sample Site: Bowden Well

Receipt Date: 11/27/2023 4:21 PM

Comments:

Sampler: Chad Kramer

Sample Matrix: Drinking Water

Project:

PO Number:

System No.: UTAH29024

Source Code: WS005

Sample Point: WS005

Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Inorganic								
Nitrate as N	0.33	10	0.10	mg/L	EPA 300.0	11/28/2023 13:00	11/28/2023 15:16	
Metals								
Arsenic, Total	0.0068	0.01	0.0005	mg/L	EPA 200.8/200.8	11/28/2023	11/28/2023	
Volatile Organic Compounds								
1,1,1,2-Tetrachloroethane	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
1,1,1-Trichloroethane	ND	200	0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
1,1,2,2-Tetrachloroethane	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
1,1,2-Trichloroethane	ND	5	0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
1,1,2-Trichlorotrifluoroethane	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
1,1-Dichloroethane	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
1,1-Dichloroethene	ND	7	0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
1,1-Dichloropropene	ND		0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
1,2,3-Trichlorobenzene	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
1,2,3-Trichloropropane	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
1,2,4-Trichlorobenzene	ND	70	0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
1,2,4-Trimethylbenzene	ND	70	1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
1,2-Dichlorobenzene	ND	600	0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
1,2-Dichloroethane	ND	5	0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
1,2-Dichloropropane	ND	5	0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
1,3,5-Trimethylbenzene	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
1,3-Dichlorobenzene	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
1,3-Dichloropropane	ND		0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
1,4-Dichlorobenzene	ND	75	0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
2,2-Dichloropropane	ND		0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
2-Chlorotoluene	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
4-Chlorotoluene	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Benzene	ND	5	0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Bromobenzene	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Bromochloromethane	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Bromodichloromethane	ND		0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Bromoform	ND		0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Bromomethane	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Carbon Tetrachloride	ND	5	1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Chlorobenzene	ND	100	0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Chloroethane	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	

Certificate of Analysis

Lab Sample No.: 23K1987-01

Name: Lakeview Water Sample Site: Bowden Well Comments: Sample Matrix: Drinking Water PO Number: Source Code: WS005	Sample Date: 11/27/2023 1:52 PM Receipt Date: 11/27/2023 4:21 PM Sampler: Chad Kramer Project: System No.: UTAH29024 Report to State: Y
---	---

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Volatile Organic Compounds (cont.)								
Chloroform	ND		0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Chloromethane	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
cis-1,2-Dichloroethene	ND	70	1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
cis-1,3-Dichloropropene	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Dibromochloromethane	ND		0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Dibromomethane	ND	5	1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Dichlorodifluoromethane	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Ethyl Benzene	ND	700	0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Hexachlorobutadiene	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Isopropylbenzene	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Methyl tert-Butyl Ether (MTBE)	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Methylene Chloride	ND	5	1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Naphthalene	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
n-Butyl Benzene	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
n-Propyl Benzene	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
p-Isopropyltoluene	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
sec-Butyl Benzene	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Styrene	ND	100	0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
tert-Butylbenzene	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Tetrachloroethene	ND	5	0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Toluene	ND	1000	0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
trans-1,2-Dichloroethene	ND	100	0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
trans-1,3-Dichloropropene	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Trichloroethene	ND	5	0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Trichlorofluoromethane	ND		1.0	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Vinyl Chloride	ND	2	0.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	
Xylenes, total	ND	10000	1.5	ug/L	EPA 524.2	11/29/2023	11/29/2023	

Certificate of Analysis

Lab Sample No.: 23K1987-02

Name: Lakeview Water	Sample Date: 11/27/2023 1:35 PM
Sample Site: Mitchell Well (East Well)	Receipt Date: 11/27/2023 4:21 PM
Comments:	Sampler: Chad Kramer
Sample Matrix: Drinking Water	Project:
PO Number:	System No.: UTAH29024
Source Code: WS001	Sample Point: WS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Inorganic								
Nitrate as N	0.35	10	0.10	mg/L	EPA 300.0	11/28/2023 13:00	11/28/2023 16:10	
Metals								
Arsenic, Total	0.0086	0.01	0.0005	mg/L	EPA 200.8/200.2	11/28/2023	11/28/2023	



Certificate of Analysis

Report Footnotes

Abbreviations

ND = Not detected at the corresponding Minimum Reporting Limit.

1 mg/L = one milligram per liter or 1 mg/Kg = one milligram per kilogram = 1 part per million.

1 ug/L = one microgram per liter or 1 ug/Kg = one microgram per kilogram = 1 part per billion.

1 ng/L = one nanogram per liter or 1 ng/Kg = one nanogram per kilogram = 1 part per trillion.

Data Comparisons

Values reported in **RED** exceed Primary Drinking Water standards.

Values reported in **BLUE** exceed Secondary Drinking Water standards.

BLANK values in the MCL column indicate no standard.

On calculated parameters, there may be a slight difference between summing the rounded values shown on the report vs the unrounded values used in the calculation.

23K1987

DRINKING WATER SAMPLES ONLY

CHEMTECH - FORD ANALYTICAL LABORATORY

CHAIN OF CUSTODY

COMPANY: Lakeview Water
 ADDRESS: ~~1630 North Orchard Way~~ PO Box 334
 CITY/STATE/ZIP: ~~Morgan, UT 84050~~ Oakley UT 84055
 PHONE #: 801-821-6944 FAX:
 CONTACT: ~~Spencer King~~ Chad Kramer PROJECT:
 EMAIL: ~~hillsideteasing@hotmail.com~~ Chad@lakeviewwatercorp.com

BILLING ADDRESS: _____
 BILLING CITY/STATE/ZIP: _____
 PURCHASE ORDER: _____



TURNAROUND TIME REQUIRED*:

* Expedited turnaround subject to additional charge

State System Number

29024

Send to State

☒ Yes ☐ No

Please fill in all blue highlighted areas. Thank you!

Lab Use Only	CLIENT SAMPLE INFORMATION						TESTS REQUESTED										Bacteria			LAB FAIL Ref #		
	LOCATION	DATE	TIME	FACILITY ID (source code)	POINT CODE (DBP)	Field: Residual Chlorine	Arsenic	Nitrate	524 VOC									Total Coliform + E. coli (Present/Absent)	Total Coliform + E. coli (Enumerated)		HPC (Plate Count)	R = Routine I = Investigative TR = Trigger Source RP = Repeat
01	1. Bowden Well	Nov 27	13:52	WS005			X	X	X													
02	2. Mitchell Well (East Well)	Nov 27	13:35	WS001			X	X														
	3.																					
	4.																					
	5.																					
	6.																					
	7.																					
	8.																					
	9.																					
	10.																					

Sampled by: [print] Chad Kramer	Sampled by: [signature] Chad Kramer	ON ICE	NOT ON ICE	Temp (C°): 6.7
Special Instructions: Chad Kramer		Samples received outside the EPA recommended temperature range of 0-6 C° may be rejected.		
Relinquished by: [signature] Chad Kramer	Date/Time 11-27-23 16:21	Received by: [signature] [Signature]	Date/Time 11/27/23 16:21	
Relinquished by: [signature]	Date/Time	Received by: [signature]	Date/Time	
Relinquished by: [signature]	Date/Time	Received by: [signature]	Date/Time	

CHEMTECH-FORD
 9632 South 500 West
 Sandy, UT 84070

801.262.7299 PHONE
 866.792.0093 FAX
www.ChemtechFord.com

Payment Terms are net 30 days OAC. 1.5% interest charge per month (18% per annum).
 Client agrees to pay collection costs and attorney's fees.

01. AP 1343
 M 1325
 V(2) B110
 02 AP 1343
 M 1325