

CROSS CONNECTION CONTROL POLICY

A policy relating to "cross connection control and backflow-prevention control" at the

LAKEVIEW WATER COMPANY

PART I:

CROSS CONNECTION CONTROL AND BACKFLOW PREVENTION

(1) It shall be against LAKEVIEW WATER COMPANY policy, at any connection supplied with water from the LAKEVIEW WATER COMPANY distribution system, to do any of the following:

- (a) To install or use any physical connection or arrangement of piping or fixtures, which may allow any fluid or substances unsuitable for human consumption to enter the potable water distribution system, as required by Section 608.1 through 608.5 of the International Plumbing Code.
- (b) To install any connection, arrangement, or fixtures without a Backflow Prevention Device or Assembly unless approved otherwise by LAKEVIEW WATER COMPANY.
- (c) To incorrectly install any Backflow Prevention Device or Assembly required by Section 608.6 and 608.1 of the International Plumbing Code.

(2) Any person found in violation of this policy shall be subject to reprimand or other appropriate disciplinary action as determined by the LAKEVIEW WATER COMPANY.

(3) Administration of this policy shall be referenced by "Cross Connection Control Program of Utah, November 2010 (Guidelines-Reference)". A copy of the manual shall be available at the office of the LAKEVIEW WATER COMPANY.

(4) Backflow prevention assemblies required by this policy will be required to be tested at least annually. The LAKEVIEW WATER system shall prepare and maintain a Backflow Assembly Information sheet on all such devices and Test results shall be maintained for a period of no less than five (5) years.

Part II:

This policy shall take effect on OCTOBER 1, 2014. A copy of the policy shall be placed in the office of the LAKEVIEW WATER COMPANY and will be reviewed for all new construction projects on a case by case basis.

Signed: Ray Bowden

Date: 9/21-14

Title: _____